

WRAS[®]

Water Regulations Advisory Scheme

This certifies that

PLASTIC FITTINGS TECHNOLOGY LTD.

has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations/Scottish Water Byelaws.

RANGE OF FP PUSHFIT FITTINGS FOR USE WITH PE-X (KITEMARKED TO BS 7291-3:201), PB (KITEMARKED TO BS 7291-2:2010) AND COPPER PIPE. FOR ABOVE GROUND USE ONLY. MAXIMUM WORKING PRESSURE & OPERATING TEMPERATURE: 12.0 BAR @ 20°C & 6.0 BAR @ 83°C.


This certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory (www.wras.co.uk/directory)

The product so mentioned will be listed in the Water Fittings and Materials Directory for a period until:


31 OCTOBER 2017

1210087

Certificate No.



Chairman, Product Approval Group



Secretary

WRAS
APPROVED
PRODUCT